

# NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

## Calabrian Corporation

Facility: Port Neches, TX

AS COMPLYING WITH NSF/ANSI 60 AND ALL APPLICABLE REQUIREMENTS.  
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE  
AUTHORIZED TO BEAR THE NSF MARK.



Certification Program  
Accredited by the  
American National  
Standards Institute



Certification Program  
Accredited by the  
Standards Council  
of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website ([www.nsf.org](http://www.nsf.org)).

December 10, 2015  
Certificate# 0R591 - 01

Theresa Bellish  
General Manager, Water Systems



The Public Health and Safety Organization

## NSF Product and Service Listings

These NSF Official Listings are current as of **Thursday, December 10, 2015** at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

---

### NSF/ANSI 60

### Drinking Water Treatment Chemicals - Health Effects

---

#### Calabrian Corporation

5500 Highway 366  
Port Neches, TX 77651  
United States  
409-727-1471

**Facility :** Port Neches, TX

#### Sodium Bisulfite[1]

*Trade Designation*

Sodium Bisulfite Solution

*Product Function*

Dechlorination

*Max Use*

46mg/L

[1] This product contains sulfite.

Sulfites have been known to cause potentially lethal allergic reactions in sulfite-sensitive individuals.

The maximum recommended allowable

residual sulfite level in the finished drinking water is 100 ppb (0.1 mg/L).

#### Sodium Metabisulfite[1]

*Trade Designation*

Sodium Metabisulfite

*Product Function*

Dechlorination

*Max Use*

15mg/L

[1] This product contains sulfite.

Sulfites have been known to cause potentially lethal allergic reactions in sulfite-sensitive individuals.

The maximum recommended allowable

residual sulfite level in the finished drinking water is 100 ppb (0.1 mg/L).

#### Sulfur Dioxide

*Trade Designation*

SO<sub>2</sub> - Sulfur Dioxide

*Product Function*

Dechlorination

*Max Use*

10mg/L